GREEN HILL RD

PRINCTON VILLAGE

NOTE:
ALL SERVICES 3-1X2/0 AL 600V
UNLESS OTHERWISE NOTED

NOTE:
LOCATION UNCERTAIN INSTALLED
PRIOR TO LOCATING.

D VILLAGE

X4/0 & 1X2/0 AL 600V
NOTED

39G1-H4

39G1-H5

EAST GOSHEN TWP.

39G1G4E

39G1-G4

TEXAS EASTERN 22" UNDERGROUND PIPELINE

39G1H3E

39G1H4E

GREENWOOD LN

CHANDLER DR

39G1H3D

39G1H4D

39G1H4F

FRANKLIN VILLAGE

FRANKLIN WY

EAST GOSHEN TWP.

39G1-GH34

39H1-AB56

PHILADELPHIA ELECTRIC COMPANY

UNDERGROUND CABLE AND CONDUIT SYSTEM

PECO ENERGY COMPANY

TABLE OF ADDITIONS & CHANGES
SINCE PRINTING SHOWING LATEST DATE

NO.	DATE	DESCRIPTION	REV'D	CHK'D	APP'D
03	09 28	EC #98516	P A D	A J H	R

CABLE AND CONDUIT MAP
UNDERGROUND CABLE AND CONDUIT SYSTEM
DELCHESTER REGION
EAST GOSHEN TWP.
SCALE: 1" = 50'-0"
PECO ENERGY COMPANY

SHEET 1 OF 1
39G1-GH34
REV 03

39G1A3G

39G1A3F

39G1A3J

39G1B3E

39G1B3H

39G1B3F

39G1A4E

39G1A4J 3-WAY

39G1A4K 3-WAY

SEE PLANEBROOK-344 FOR LAYOUT

39G1A4F

39G1A4G

39G1A4H

39G1B4E

39G1B4D

39G1A5D

39G1B5D

2-WAY 1N BOX PAD

NOTE:
ALL SERVICES 2-1X4/0 & 1X2/0 AL 600V
UNLESS OTHERWISE NOTED

NOTE:
LOCATION UNCERTAIN INSTALLED
PRIOR TO LOCATING.

STUB/CAP 2" CD.
FOR FUTURE
POOL MOTOR

39H1-AB34
39H1-CD34

39H1-AB56

39H1C4E

39H1C3E

39H1B4F

DELCHESTER REGION

39H1-AB34 03

SHEET 1 OF 2

A-A	3-1X1/0 AL CONC 35KV	B-B	4" P. DT. 3-1X1/0 AL CONC 35KV	C-C	1X1/0 CONC & 1X4/0 AL 35KV	D-D	#1 1x1/0 AL CONC 35KV; #2 2-1X4/0 & 1X2/0 AL 600V
E-E	2-1X500 & 1X4/0 AL 600V	F-F	#1 1x1/0 AL CONC 35KV; #2 1X1/0 AL CONC 35KV (ABAND)	G-G	2-4" P. DT. #1 1x1/0 AL CONC 35KV; #2 1X1/0 AL CONC 35KV (ABAND)	N-N	#1 2-1x1/0 AL CONC 35KV; #2 2-1X4/0 & 1X2/0 AL 600V
H-H	#1 1X1/0 AL CONC 35KV; #2 1X1/0 AL CONC 35KV (ABAND); #3 2-1X4/0 & 1X2/0 AL 600V	J-J	4" P. DT. 1X1/0 CONC & 1X4/0 AL 35KV	K-K	#1 1X1/0 AL CONC 35KV; #2 #3 2-1X4/0 & 1X2/0 AL 600V	L-L	4" P. DT. 1X1/0 CONC & 1X4/0 AL 35KV
M-M	2-1X4/0 & 1X2/0 AL 600V						
P-P	#1 1x1/0 AL CONC 35KV (3" P. DT.); #2 1X1/0 AL CONC 35KV (4" P. DT.) DEAD & ABANDON	O-O	#1 1x1/0 AL CONC 35KV (3" P. DT.); #2 1X1/0 AL CONC 35KV DEAD & ABANDON; #3 2-1X4/0 & 1X2/0 AL 600V				

D:\c&c\39\39G1GH34.DGN 7/26/2023 11:06:58 AM